

# Annexure C


Appendix-XIII

## CERTIFICATE SAFE DRINKING WATER AND SANITARY CONDITION.

URN No: - TC996423000000752F

Dated: 24/06/2024

It is certified that an inspection team headed by MR. NAVEEN SURI SAMPLING ASSISTANT (LABORATORY) from , UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY inspected the THE GURU, KASHMIRI KHOTHI, DELHI NAINITAL MINI BYPASS, KARAMCHARI NAGAR ROAD , BAREILLY, UTTAR PRADESH on 24/06/2024 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

Signature with Seal: 

Name :

**Vipin Kumar Singh**  
Assistant Engineer


Designation: .....U.P. Jal Nigam, Bareilly (R)

Assistant Engineer of  
The Govt. Public Health Department  
(PHED)/Authorized officer of the Local Body

Name & Address of the Office / Department:-


U.P. JAL NIGAM BAREILLY (RURAL).



For THE GURU

  
Manager

To  
MANAGER


THE GURU, KASHMIRI KHOTHI,  
DELHI NAINITAL MINI BYPASS, KARAMCHARI NAGAR ROAD,  
BAREILLY, UTTAR PRADESH

  
Principal  
THE GURU  
Kashmiri Kothi, Karamchari Nagar  
Nainital Delhi Road, Near Petrol Pump  
Bareilly, Uttar Pradesh-243122


Analysis Report						
		District Level Water Analysis Laboratory U.P. Jal Nigam (RURAL)				
		Near M.B. Inter Collage, Gandhi Nagar, Bareilly (U.P.)				
Customer Details						
Office Name and Address		THE GURU , KASHMIRI KHOTHI , DELHI NAINITAL MINI BYPASS, KARAMCHARI NAGAR ROAD BAREILLY.				
Ref Letter No & Date		TG/015	DATE - 24.06.2024	Report No.- LAB/BLY/2023-24/752		
Basic details of sample						
District	BAREILLY	Tehseel	BAREILLY	Analysis Start Date	24.06.2024	
Village	KARAMCHARI NAGAR	Block		Analysis Completion Date	24.06.2024	
Habitation	KARAMCHARI NAGAR	Location	IN SCHOOL ( THE GURU )	Sample Code	PS- 752	
Water Source	Submersible	Date of Sample Collection	24.06.2024	Report Issue Date	25.06.2024	
Quantity of Sample	2 ltr	Sample Collector	VIPIN KUMAR	Sample Depositor	DEEPAK MORYA	
Receiving Date	24.06.2024					
Environmental Condition						
Temperature		27°C		Humidity		58%
Technical Data of Analysis						
S.No.	Analysis Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Colour	(Hazen)	0	5	15	IS 3025 (Part 4):2021
2	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022
3	Taste	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022
4	Turbidity	(NTU)	0.16	1.00	5.00	IS 3025 (Part 10) : 2022
5	TDS	(mg/L)	177	500	2000	IS 3025 (Part 16) : 2022
6	PH	-	7.92	6.5-8.5	6.5-8.5	IS 3025 (Part 11) :2022
7	Iron	(mg/L)	0.2	1.00	1.00	IS:3025(Part-53):2014
8	Sulphate	(mg/L)	10.2	200	400	IS-3025 (Part 24) : 2022
9	Alkalinity	(mg/L)	120	200	600	IS 3025 (Part 23) : 2019
10	Hardness	(mg/L)	118	200	600	IS 3025 (Part 21) : 2019
11	Chloride	(mg/L)	6	250	1000	IS 3025 (Part 32) : 2019
12	Calcium	(mg/L)	96	75	200	IS:3025(Part-40):2019
13	Magnesium	(mg/L)	5.3	30	100	IS:3025(Part-40):2019


Page no:-1/1


Email - anamika05anu@gmail.com  
U.P. J.N. BAREILLY (RURAL) Cont.No:- 7318253236



  
 Prepared By  
 अनिल कुमार  
 गुणवत्ता प्रबन्धक  
 जल विश्लेषण प्रयोगशाला  
 उ० प्र० जल निगम बरेली (ग्रामीण)

END OF THE REPORT

  
 Authorized signatory  
 अनामिका सिंह  
 तकनीकी प्रबन्धक  
 जल विश्लेषण प्रयोगशाला  
 उ० प्र० जल निगम, बरेली (ग्रामीण)


FOR THE GURU  
  
 Manager



  
 Principal  
 THE GURU  
 Kashmiri Kothi, Karamchari Nagar  
 Nainital Delhi Road, Near Petrol Pump  
 Bareilly, Uttar Pradesh-243122

		Analysis Report					
		District Level Water Analysis Laboratory U.P. Jal Nigam (RURAL)					
		Near M.B. Inter Collage, Gandhi Nagar, Bareilly (U.P.)					
<b>Customer Details</b>							
Office Name and Address		THE GURU , KASHMIRI KHOTHI ,DELHI NAINITAL MINI BYPASS, KARAMCHARI NAGAR ROAD BAREILLY.					
Ref Letter No & Date		TG/015		DATE - 24.06.2024		Report No.- LAB/BLY/2023-24/752	
<b>Basic details of sample</b>							
District	BAREILLY	Tehseel	BAREILLY	Analysis Start Date	24.06.2024		
Village	KARAMCHARI NAGAR	Block		Analysis Completion Date	24.06.2024		
Habitation	KARAMCHARI NAGAR	Location	IN SCHOOL ( THE GURU )	Report Issue Date	25.06.2024		
Water Source	Submersible	Sample Code	PS- 752	Sample Depositor	DEEPAK MORVA		
Quantity of Sample	2 ltr	Date of Sample Collection	24.06.2024	Sample Collector	VIPIN KUMAR		
Receiving Date	24.06.2024						
<b>Environmental Condition</b>							
Temperature		27°C		Humidity		58%	
<b>Technical Data of Analysis</b>							
S.No.	Analysis Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref.Method of Analysis	
				Acceptable Limit	Permissible Limit		
1	E-Coli	(CFU/100ml.)	0.00	No relaxation	No relaxation	APHA 23trd Edition : 2017,9222-B	
2	T-Coliform	(CFU/100ml.)	0.00	No relaxation	No relaxation	APHA 23trd Edition : 2017,9222-B	
<b>Note</b>							
1. This Certificate refers only to the particular sample(s) submitted for testing.							
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.							
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.							
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.							

Page no:-1/1

END OF THE REPORT

For THE GURU  
  
 Manager

  
 Tested By  
**शिवानी**  
 माइक्रोबायोलॉजिस्ट  
 जल विश्लेषण प्रयोगशाला  
 उ०प्र० जल निगम, बरेली (ग्रामीण)  
  
 Principal  
 THE GURU  
 Kashmiri Kothi, Karamchari Nagar  
 Nainital Delhi Road, Near Petrol Pump  
 Bareilly, Uttar Pradesh-243122